

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-0785:157

Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Model SP40/2 voice evacuation unit. Unit does not sense an emergency condition, but when initiated from a control unit, can provide pre-recorded messages and/or live voice messaging via a local microphone. The SP40/2 also features night ring (NR), telephone paging (TEL) and background music (BGM) which are not operational during alarm conditions. These features will not operate if the system is only powered by a secondary source. System components:

SP40/2	Mainboard
MIC 400	Local Microphone
SP40/2 Enclosure	Enclosure Backbox
SPRM	Safepath Remote Microphone
SP4Z-B	4 Zone Class B Speaker Audio Splitter
SPB-160, *SPB-80/4	Audio Boosters
SP4Z-A/B	2 Zone Class A, 4 Zone Class B Audio Splitter
*SPMB-4Z	Mounting Bracket

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

	<u>SP40/2</u>	<u>SPB-160</u>	<u>*SPB-80/4</u>
Primary:	120 VAC, 2.15A 240 VAC, 1.10A	160W Audio Output	80 W, Audio Output
Secondary:	24 VDC, 4.3A		24 VDC, 2A NAC Circuit

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice evacuation unit when used in conjunction with separately listed electrically and functionally compatible fire alarm control units.

NOTE: The telephone paging is not to be used for emergency use.

*Rev. 11-19-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 19, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**